

Solar EPC

Solar EPC

Site Simulation Report

- PV Syst Report

Module Layout

- Total module mounting layout

Erection of structure & module mounting

- Module , Inverter , ACDB Installation

Drawings

- Single Line Diagram
- G.A. Diagram
- L.A. & Earthing Layout

CEIG Approval

- Government Approvals

Project Completion Report

- Final Handover report after completion of Project

Site Simulation Report

PVSYST V6.78	AKSHITA ASSOCIATES	Page 1/5
Grid-Connected System: Simulation parameters		
Project : ETL B1/3		
Geographical Site	Chakan	Country India
Situation	Latitude 18.74° N	Longitude 73.81° E
Time defined as	Legal Time Time zone UT+5.5	Altitude 446 m
Meteo data:	Chakan	Synthetic
Simulation variant : MACHINE SHOP 2		
	Simulation date	04/09/19 18h15
	Simulation for the	1st year of operation
Simulation parameters	System type	No 3D scene defined, no shadings
2 orientations	tilts/azimuths	15°/0° and 15°/180°
Models used	Transposition	Perez Diffuse Perez, Meteorom
Horizon	Free Horizon	
Near Shadings	No Shadings	
User's needs :	Unlimited load (grid)	
PV Arrays Characteristics (2 kinds of array defined)		
PV module	Si-poly Model	Eldora VSP.72.330.05
Original PVsyst database	Manufacturer	Vikram Solar
Sub-array "SOUTH Side"	Orientation	#1 Tilt/Azimuth 15°/0°
Number of PV modules	In series	18 modules In parallel 36 strings
Total number of PV modules	Nb. modules	648 Unit Nom. Power 330 Wp
Array global power	Nominal (STC)	214 kWp At operating cond. 194 kWp (50°C)
Array operating characteristics (50°C)	U mpp	614 V I mpp 316 A
Sub-array "NORTH side"	Orientation	#2 Tilt/Azimuth 15°/180°
Number of PV modules	In series	19 modules In parallel 4 strings
Total number of PV modules	Nb. modules	76 Unit Nom. Power 330 Wp
Array global power	Nominal (STC)	25.08 kWp At operating cond. 22.73 kWp (50°C)
Array operating characteristics (50°C)	U mpp	648 V I mpp 35 A
Total Arrays global power	Nominal (STC)	239 kWp Total 724 modules
	Module area	1405 m²
Inverter	Model	SUN2000-50KTL-M0_400Vac
Custom parameters definition	Manufacturer	Huawei Technologies
Characteristics	Operating Voltage	200-1000 V Unit Nom. Power 50.0 kWac
		Max. power (=>49°C) 55.0 kWac
Sub-array "SOUTH Side"	Nb. of inverters	21 * MPPT 17 % Total Power 175 kWac
		Pnom ratio 1.22
Sub-array "NORTH side"	Nb. of inverters	3 * MPPT 17 % Total Power 25 kWac
		Pnom ratio 1.00
Total	Nb. of inverters	4 Total Power 200 kWac
PV Array loss factors		
Array Soiling Losses		Loss Fraction 3.0 %
Thermal Loss factor	Uc (const) 29.0 W/m ² K	Uv (wind) 2.5 W/m ² K / m/s
Wiring Ohmic Loss	Array#1 17 mOhm	Loss Fraction 0.8 % at STC
	Array#2 161 mOhm	Loss Fraction 0.8 % at STC
	Global	Loss Fraction 0.8 % at STC
Serie Diode Loss	Voltage Drop 0.8 V	Loss Fraction 0.1 % at STC


Grid-Connected System: Main results

Project : ETL B1/3
Simulation variant : MACHINE SHOP 2
 Simulation for the 1st year of operation


Main system parameters	System type	No 3D scene defined, no shadings
PV Field Orientation	2 orientations	Tilt/Azimuth = 15°/0° and 15°/180°
PV modules	Model	Eldora VSP.72.330.05 Pnom 330 Wp
PV Array	Nb. of modules	724 Pnom total 239 kWp
Inverter	Model	SUN2000-50KTL-M0_400Vac 50.0 kW ac
Inverter pack	Nb. of units	4.0 Pnom total 200 kW ac
User's needs	Unlimited load (grid)	

Main simulation results
 System Production **Produced Energy 360.8 MWh/year** Specific prod. 1510 kWh/kWp/year
 Performance Ratio PR **76.93 %**

Normalized productions (per installed kWp): Nominal power 239 kWp



Performance Ratio PR



MACHINE SHOP 2 Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray MWh	E_Grid MWh	PR
January	157.5	34.72	24.04	182.4	171.6	34.81	34.04	0.781
February	161.0	36.96	25.03	178.6	168.4	33.89	33.13	0.776
March	200.9	48.36	27.01	211.2	198.7	39.49	38.58	0.765
April	205.8	54.90	27.46	205.3	193.2	38.49	34.01	0.693
May	203.7	65.72	26.75	195.5	183.5	37.10	36.28	0.777
June	130.2	71.70	25.34	123.9	115.3	23.81	23.33	0.788
July	109.1	70.06	24.45	104.8	97.3	20.26	19.86	0.794
August	110.4	69.13	23.90	108.3	100.6	21.02	20.63	0.797
September	134.4	64.50	23.81	137.6	128.4	26.61	26.07	0.793
October	158.4	52.39	25.38	171.4	160.7	32.70	32.01	0.782
November	149.7	38.10	25.54	171.3	161.1	32.72	30.49	0.745
December	146.9	34.41	24.14	172.5	162.3	33.03	32.31	0.784
Year	1868.0	640.95	25.24	1962.7	1841.2	373.94	360.75	0.769


Legends: GlobHor Horizontal global irradiation GlobEff Effective Global, corr. for IAM and shadings
 DiffHor Horizontal diffuse irradiation EArray Effective energy at the output of the array
 T_Amb Ambient Temperature E_Grid Energy injected into grid
 GlobInc Global incident in coll. plane PR Performance Ratio

Grid-Connected System: Loss diagram

Project : ETL B1/3
Simulation variant : MACHINE SHOP 2
 Simulation for the 1st year of operation

Main system parameters	System type	No 3D scene defined, no shadings		
PV Field Orientation	2 orientations	Tilt/Azimuth = 15°/0° and 15°/180°		
PV modules	Model	Eldora VSP.72.330.05	Pnom	330 Wp
PV Array	Nb. of modules	724	Pnom total	239 kWp
Inverter	Model	SUN2000-50KTL-M0_400Vac		50.0 kW ac
Inverter pack	Nb. of units	4.0	Pnom total	200 kW ac
User's needs	Unlimited load (grid)			

Loss diagram over the whole year



Module Layout



Erection of structure and module mounting


Structure Building



Module Mounting



Railings



Inverter



Total Installation




ACDB



Drawings

Single line Diagram




	PV MODULE
	SPD
	CURRENT TRANSFORMER
	MCCB
	MCCB
	INVERTER
	INDICATOR LAMP
	SOCKET

PROJECT SUMMARY	
PLANT DC CAPACITY	600.2 kWp
PLANT AC CAPACITY	480 kW
TOTAL NO. OF PV MODULES	1550 NOS
SOLAR PV MODULE	RENESOLA 385 Wp
MODULE TYPE	MONOCRYSTALLINE
PV MODULE DIMENSIONS	1958 X 902 mm
GAP BETWEEN PV MODULES	20 mm
MODULE TILT ANGLE	FLUSHMOUNT

REV	20-10-2020	CONSTRUCTION STAGE DRAWING	AS	-
E	10-11-20	E	10-11-20	10/11/20
CLIENT - ENDURANCE TECHNOLOGY LIMITED B22				
DEVELOPER - Akhita Associates				
PROJECT - B22_600.2 kWp				
LOCATION - Chakan,Pune,Maharashtra				
TITLE - SINGLE LINE DIAGRAM				
DATE	20-10-2020	DATE OF CHECKING	SCALE	REV NO.
DRAWN	20-10-20	CHECKED	N.T.S.	R1
DATE OF ISSUE	20-10-2020	APPROVED		
PROJECT - R1-001				


G.A. Diagram



PANEL-SOLAR PANEL
 CABLE ENTRY- TOP SIDE
 COATING- RAL-7035
 PANEL SIZE- 1800X1700X500(D)

D					DRG. NO.	SHEET
C					DWG/2019-20/258	1/2
B					CUSTOMER	REV
A	30/09/20	DRAWINGS BUILT	APR. INTL.	USER		A
REV	DATE	MODIFICATION	DRAWN	CHECKED		

L.A & Earthing Layout



CEIG Approval



१८५१५४१४०४३१२१२१३३६

महाराष्ट्र शासन

अधीक्षक अभियंता, औरंगाबाद

उद्योग, ऊर्जा व कामगार विभाग

अधीक्षक अभियंता, औरंगाबाद अधीक्षक अभियंता प्रादेशिक विद्युत निरीक्षण मंडळ, शिवदास ट्रेड सेंटर, प्लॉट नं.११, हॉल नं.४, पहिला मजला, त्रिमुर्ती चौक, जवाहर कॉलनी, हेडगेवार हॉस्पिटल रोड, औरंगाबाद-४३१००५

E-mail ID : seaurangabad.nrg-mh@gov.in

Permission No.: ०SE५१५००५०३२०१९००६९१

दूरध्वनी क्र. : ०२४०-२४८७०४६

दिनांक : ०५/०३/२०१९

प्रति,

ANURANG NARESH CHADRA JAIN ,
ENDURANCE TECHNOLOGIES LTD

विषय :- ENDURANCE TECHNOLOGIES LTD. PLOT NO.२२६/१, येथील २६२ कॅव्हीए क्षमतेची Industrial कारणासाठी @SubCategoryType विद्युत निर्मिती संच मांडणी कार्यान्वित करण्यास कायमस्वरूपी परवानगी देण्याबाबत.

संदर्भ :- १) नकाशा मंजूरी क्रमांक: १८५१५४१४०४३१९१E०AA०BE दिनांक: ०१/०३/२०१९

२) M/S ANURANG NARESH CHADRA JAIN यांचे पत्र क्र १८५१५४१४०४३१२१३३६ दिनांक: ०५/०३/२०१९

वरील संदर्भांकित विषयास अनुसरून वर उल्लेखलेल्या ठिकाणच्या जनित्रसंचमांडणीचे निरीक्षण ह्या कार्यालया मार्फत दिनांक: ०५/०३/२०१९ रोजी करण्यात आले. त्यास केंद्रीय विद्युत प्राधिकरण (विद्युत पुरवठा व सुरक्षा संबंधी उपाय योजना) विनियम २०१० चे विनियम ३२ अन्वये कार्यान्वित करण्याची कायमस्वरूपी परवानगी याद्वारे खालील अटीच्या अधीन राहून देण्यात येत आहे.

- १) विद्युत कायदा २००३ व केंद्रीय विद्युत प्राधिकरण विनियम २०१० (व सुधारीत विनियम २०१५ मधील तरतुदीचे सुरक्षिततेच्या दृष्टीने काटेकोर पालन करावे.
- २) जनित्रसंचमांडणीतील बदल देखभाल व दुरुस्ती केंद्रीय विद्युत प्राधिकरण विनियम २०१० चे विनियम २९ अन्वये परवानाधारक विद्युत ठेकेदार/प्राधिकृत व्यक्तीमार्फतच करण्यात यावी. यात दुर्लक्ष केलेले आढळल्यास त्यास आपण सर्वस्वी जबाबदार राहाल याची नोंद घ्यावी .
- ३) जनित्र निर्मित वीज उत्पादनाची नोंदवही विहित नमुन्यात ठेवावी.
- ४) नियमित परतावे व विद्युत शुल्क मुदतीत भरणे जनित्र धारकास बंधनकारक आहे.
- ५) विद्युत निरीक्षकाच्या पूर्व परवानगी शिवाय सदर संचमांडणीत कोणताही फेरबदल करू नये अन्यथा सदर परवानगी आपोआप रद्द होईल याची नोंद घ्यावी.
- ६) सदर संचमांडणी ६ महिन्यात कार्यान्वित न केल्यास ग्राह्य राहणार नाही.
- ७) विद्युत संचमांडणीच्या प्राप्त चाचणी अहवालानुसार त्याच्या सत्यतेची जबाबदारी मे.म.ठे.क्र VEDANT ENERGY SOLUTIONS LLP , ३२३०१ म.प.क्र ५३०९६ या विद्युत ठेकेदाराची राहिल
- ८) प्रत्यक्ष जोडभार/ वापरानुसार नियंत्रक स्थिचिअर रिलेचे सेटिंग करून घेणे बंधनकारक राहिल.
- ९) जनित्र वापर- कॅप्टीव्ह / त्रयस्थ फ्ल वापर

Signature valid
Digitally Signed by
ASHOK GANPATI
KANAS

Date:05-03-2019 11:44:25

Project Completion Report

Project Completion Report

Project Name	Shree Pressings L15 MIDC Waluj Aurangabad.
Project Capacity	150 KWp DC
Project Commissioning Date	08 Aug 2020

Purpose:

The purpose of the project is to install Solar PV power project, and synchronize the output to the local grid to meet the self-electricity requirement

Project Scope:

Scope	Remark
Designing of the Solar PV project	Completed
Supply of Solar inverter, Module mounting structure, AC & DC Cables, ACDB, AC & DC Switchgear, Protection Device, Earthing material, Lighting Arrestor, Solar Energy Meter	Completed
Erection of the project	Completed
Commissioning of the project	Completed
Installation of Zero Export Controller	Not Applicable
Operation & Maintenance Contract Signed	Not Signed

Feedback

Objective	Satisfactory Level (Excellent/Good/Average/Poor)
Quality of Product	
Workmanship	
Timeline management	
No Leakage from Roof	

Sign – off:

By signing this report we agree to the completion of the 150 KWp Solar PV project in all respect, and found it to be satisfactory.

For Shree Pressings

For Akshita Associates

Authorized Signatory

Authorized Signatory

